



Sub Divisional Level Water Testing Laboratory



UTTARAKHAND JAL SANSTHAN HALDWANI, NAINITAL

Water Quality Test Report


Name of the Customer/ Organization:	DELHI PUBLIC SCHOOL HALDWANI Near Bel Baba Mandir, Haripur- Phutkuwa Rampur-Road.	Sample Description	DELHI PUBLIC SCHOOL HALDWANI Near Bel Baba Mandir, Haripur- Phutkuwa Rampur- Road.
Type of Water (Surface water/Ground water)	Drinking -Water	Start of analysis	07.06.2023
Sample Code:	DPS-60	Sample collected By	Customer
Sample Receiving Date and Time:	07.06.2023 11.35Am	Date of Issue Report	13.06.2023

Testing Details

S.N.	Parameters	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Results
1	Colour (Hazen units)	5	15	Less Than 05
2	Odour (Agreeable)	Agreeable	Agreeable	Agreeable
3	pH@25*c	6.5 to 8.5	No relaxation	7.93
4	Alkalinity as CaCo ₃ (mg/l)	200	600	236
5	Turbidity (NTU)	1	5	0.38
6	Total dissolved solid (mg/l)	500	2000	288
7	Chloride (mg/l)	250	1000	5.4
8	Total hardness (mg/l)	200	600	228
9	Calcium(as ca) (mg/l)	75	200	80.8
10	Magnesium (mg/l)	30	100	6.3
11	Total coliform (MPN/100ML)*	Absent	Absent	ABSENT
12	E.Coli (MPN/100ML)*	Absent	Absent	ABSENT


*Indicates-Parameters that are not NABL-accredited.

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.


CHEMIST
SDLWQTML,
UJS Haldwani (Nainital)




PRINCIPAL
DELHI PUBLIC SCHOOL, HALDWANI
(Under the Aegis of DPS Society New Delhi
(Uttarakhand))


Technical Manager In-charge of lab
TECHNICAL MANAGER
(Sub-Divisional Level)
Water Quality Testing
& Monitoring Laboratory
UJS- Haldwani (Nainital)

END OF REPORT