

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 3049

Dated: 28-2-25

It is certified that an inspection team headed by ...Dr. Manoj Kandpal...

(Name of Officers with designation) from ...Nagar Nigam, Haridwar, PHED

inspected the Delhi Public School, Haripur, Phutkura, Rampur Road

(Name & Address of the school) on 22/02/2025.....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. DPS-73.....dated 19/02/2025

of Uttarakhand, Ja. Sanathan, Haridwar (PHED Lab) certified that the

Delhi Public School, Haripur, Phutkura, Rampur Road (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till ...22/02/2025 to 21/02/2026

Signature with Seal: [Signature]

Name

Designation

Name & Address of the Office / Department

To
Delhi Public School, Haripur, Phutkura
Rampur Road
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Sub Divisional Level Water Testing Laboratory

UTTARAKHAND JAL SANSTHAN
HALDWANI, NAINITAL

Name of the Customer/ Organization:	Delhi Public School Near Bel Baba Mandir Haripur phutkuwa Rampur Road Haldwani.	Sample Description	Delhi Public School Near Bel Baba Mandir Haripur phutkuwa Rampur Road Haldwani.
Type of Water (Surface water/Ground water)	Drinking-Water	Start of analysis	17-02-2025
Sample Code:	DPS-31	Sample collected By	Customer
Sample Receiving Date and Time:	17.02.2025 10.40 Am	Date of Issue Report	19-02-2025

Water Quality Test Report

Testing Details

S.N.	Parameters	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Results
1	Colour (Hazen units)	5	15	05
2	Odour (Agreeable)	Agreeable	Agreeable	Agreeable
3	pH@25*c	6.5 to 8.5	No relaxation	7.97
4	Alkalinity as CaCo3 (mg/l)	200	600	210
5	Turbidity (NTU)	1	5	0.64
6	Total dissolved solid (mg/l)	500	2000	260
7	Chloride (mg/l)	250	1000	5.4
8	Total hardness (mg/l)	200	600	180
9	Calcium(as ca) (mg/l)	75	200	57.6
10	Magnesium (mg/l)	30	100	8.74
11	Total coliform (MPN/100ML)*	Absent	Absent	ABSENT
12	E.Coli (MPN/100ML)*	Absent	Absent	ABSENT

CHEMIST,
SDLWQTML,
UJS Haldwani (Nainital)

Technical Manager In- charge of lab
UJS Haldwani (Nainital)
TECHNICAL MANAGER
Sub- Divisional Level
Water Quality Testing
& Monitoring Laboratory
UJS- Haldwani (Nainital)

***END OF REPORT**